SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2853

Dated: 17/04/2024

Technician from IDSP UNIT, Ghaziabad inspected the SHREE RAM PUBLIC HIGHER SECONDARY SCHOOL, VILLAGE SHAKOORPUR MODINAGAR GHAZIABAD on 13/04/2024 and on the basis of Water Test Report bearing no. DSO/IDSP/2024/...... dt. 17/04/2024 of IDSP, Ghaziabad certified that the SHREE RAM PUBLIC HIGHER SECONDARY SCHOOL, VILLAGE SHAKOORPUR MODINAGAR GHAZIABAD has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by State Government. This certificate is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand cancelled on proof.

Validity upto one year.

(Dr. R K Gupta)

District Public Health Expert

Chaziabad

District Surveillance Onesa

District Public Health Expert District Ghaziabad

To SHREE RAM PUBLIC HIGHER SECONDARY SCHOOL, VILLAGE SHAKOORPUR MODINAGAR GHAZIABAD

Office of the Chief Medical Officer, Ghaziabad

Ref.No. DSO/IDSP/2024 / 2853

Dated: 17/04/2024

WATER TEST REPORT

ADDRESS:- SHREE RAM PUBLIC HIGHER SECONDARY SCHOOL, VILLAGE SHAKOORPUR **MODINAGAR GHAZIABAD**

PREVIOUS SAMPLE	parties and the same and the sa	SAMPLE WATER WAS	SAMPLE ID	RESULT
COLLECTION DATE N/A	N/A	N/A	N/A	N/A

NO of Sample collected: 01

cted . OI		T	DECLUT
SAM LE COLLEGIA	SAMPLE WATER WAS BEING USED	SAMPLEID	RESULT
RO WATER	DRINKING	2296	Satisfactory
	SAMPLE COLLECTION AREA	SAMPLE COLLECTION SAMPLE WATER WAS BEING USED	SAMPLE COLLECTION SAMPLE WATER WAS BEING USED SAMPLE ID

Test Result

H₂S Water test Kit

Negative (-Ve) after 24-48hrs incubation

Comments:-

H₂S Water test Kit report – ve reflects that water is free from Coliforms Organism.

Recommendation:

Given Water is safe for Drinking Purpose.

Validity upto one year.

Microbiologist ISDP Lab

Ghaziabad

(Dr. R.K Gupta)

District Public Health Expert

District daily bridge Office District Public Health Extra. District Chaziabad